

Frequency of Periodic Inspections

Technical Standards and Safety Authority (Ontario)

	Object Description	Years
A	Deaerator	1 year
B	High Pressure Boiler	1 year
C	Low Pressure Boiler	2 years
D	Pressure vessel (PV)	3 years
E	PV with Quick opening doors	1 year